

## ročný report Kk za 2016

	CO	NOx	SO2	TZL
Tech.jednotky	mg/m3nr	mg/m3nr	mg/m3nr	mg/m3nr
Emisný Limit	246,77	477,95	631,06	43,42
TC (I) %				
N 48h > 1.1EL	0	0	0	0
% 48h <1.1EL	100	100	100	100
N / %PDH F	1/0.3	1/0.3	1/0.3	1/0.3
c-vážený priem. mg/m3< EL	22,00	249,82	425,80	10,19
Množstvo ZL [kg]/den< EL	22904	260055	443242	10598
Q spal. tis.[m3 ns]/den< EL	1040965	1040965	1040965	1039627
c-vážený priem. mg/m3> EL				103,323
Množstvo ZL [kg]/den> EL	0,000	0,000	0,000	8,42
Q spal. tis.[m3 ns]/den> EL	0,000	0,000	0,000	81,50

mesiac	Bez	stav	Nabeh	zast.	ZmQ	CO	NOx	SO2	TZL
	-	""	N	Z	Q	mg/m3nr	mg/m3nr	mg/m3nr	mg/m3nr
01.2016	0,0	744,0	0,0	0,0	0,0	13,9	395,6	940,2	17,4
02.2016	1,0	693,0	1,0	1,0	0,0	8,8	412,5	834,1	15,3
03.2016	1,0	741,0	1,0	1,0	0,0	26,3	403,2	681,1	15,6
04.2016	5,0	713,0	1,0	1,0	0,0	61,7	351,7	12,0	14,1
05.2016	3,0	739,0	1,0	1,0	0,0	54,3	264,2	10,3	8,1
06.2016	26,0	677,0	10,0	7,0	0,0	72,8	250,3	12,0	6,4
07.2016	66,0	672,0	3,0	3,0	0,0	92,3	272,6	12,1	8,8
08.2016	0,0	744,0	0,0	0,0	0,0	75,7	272,0	10,1	8,5
09.2016	0,0	720,0	0,0	0,0	0,0	63,5	279,6	12,7	10,1
10.2016	26,0	697,0	11,0	10,0	0,0	56,0	343,7	145,9	11,1
11.2016	4,0	712,0	2,0	2,0	0,0	24,4	381,3	908,1	16,5
12.2016	1,0	741,0	1,0	1,0	0,0	12,1	409,2	1083,3	18,3
Sum/Priem	133,0	8593,0	31,0	27,0	0,0	46,73	336,30	388,98	12,54